

Manufacturer: **ECOSOFT SPC Ltd.**
1 I, Pokrovska Str., Irpin town
Kiev region, Ukraine

Product: **Industrial Reverse Osmosis systems ECOSOFT**

Type: **MO NNNN W F C OOOOO**
where :
NNNN-number of membrane elements, W-water type, F-frame and pipe
system material, C-controller type, OOOOO-other options (optional)

This conformity certificate confirms the conformity of the product with essential safety requirements of the following EC/EU New Approach Directives as amended:

2006/42/EC MD Directive
2014/35/EU LVD Directive
2014/30/EU EMC Directive

Harmonized standards used for the conformity assessment:

EN ISO 12100:2010
EN 809:1998+A1:2009/AC:2010
EN 60204-1:2018
EN 61000-6-2:2005/AC:2005
EN 61000-6-3:2007/A1:2011/AC:2012

The certificate has been issued on the basis of the tests of the product type sample. The results are recorded in the Conformity assessment report No. 240500240/3 dated 08.10.2024



mark can be used only in the case of conformity assessment according to all relevant EC/EU Directives

This certificate is issued under the following conditions:

1. The certificate applies to the product type and its variations specified in the above mentioned Conformity Assessment report.
2. The production process/factory production control is not covered by this certificate.
3. The certificate does not imply that the certification body has performed any surveillance or control of the production process.
4. The manufacturer shall ensure the conformity of subsequent production items with the certified type.
5. Changes that may have an impact on maintaining conformity with the certification requirements may require confirmation of the validity of the certificate by demonstrating compliance with the conditions under which the certificate was issued or by conducting an additional evaluation.
6. The holder of this certificate must keep the conditions specified in the General Rules for Product Certification, which are freely available at www.tsu.eu.

Sicherheitshinweise und Warnhinweise

Industrial Reverse Osmosis systems Ecosoft_?? (1)

- Anlagen nur mit geeigneter Vorbehandlung und innerhalb der zulaessigen Betriebsdaten betreiben.
- Elektrische Arbeiten nur durch qualifizierte Personen ausfuehren; vor Servicearbeiten spannungsfrei schalten.
- Druckleitungen, Pumpen und Membrangehaeuse vor Arbeiten drucklos machen.
- Permeat nach laengerem Stillstand verwerfen und Anlage vor Nutzung spuelen.
- Chemikalien zur Reinigung oder Konservierung nur gemaess Sicherheitsdatenblatt einsetzen.
- Leckagen sofort beheben. Aufstellort gegen Wasserschaden absichern.

Im Notfall Wasserzufuhr absperrern, Anlage ausser Betrieb nehmen und bei Personen- oder Sachgefahr geeignete Hilfe verstaendigen. Fuer Trinkwasseranwendungen regelmaessige Kontrolle und Wartung dokumentieren.

Technische Änderungen vorbehalten